

Application Fields:
Orion Echo Ultrasonic Level Probe is used for continuous level measuring and volume measuring of liquid and solid materials in open and closed tanks without contact. Furthermore the device has an open channel flow measuring option. There is 4 key leak proof keypad and it can show the measured value as level, distance (cm, m, inch or feet) or volume (liter, m3, imp and gallon).

Selection of Fields of Application:

- Water treatment and process technology: Water, waste water etc.
- Food industry: Beverage, milk and milk products etc.
- Chemical and pharmaceutical industry: Oil, gasoline, diesel etc. (PVDF sensor)
- Distance and movement control : Woodworking, mechanical engineering

Function:
Ultrasonic sensor sends short pulses of high frequency (50 KHz) ultrasonic sound with piezoelectric transducer. Some of the ultrasonic sound waves which are reflected by hitting to measuring surface are perceived by transducer, thus distance of the objects is determined depending on speed of signal in air.

Technical Specifications

Electricity Properties


Connection Terminal: Max. 2 mm² (AWG 14) cross-sectioned cable inlet
Fitting : PG9
Supply Voltage : ECH3XX- 24V DC ±30% max. 4 W
Control Relay : 2 pcs changeover NO contact AC max. 250 V, 1A
Analog Outlet : ECH3XX- 4-20 mA isolated (2 KV) 14 bit/HART option
Serial Port : ECH3XX- 4-20 mA isolated (2 KV) 14 bit/HART option
Protection Class : IP68 (Modbus RTU (38400 Bps max))
is fastened by using cable having thickness of 4-8mm

Mechanical Properties

Box : A: Aluminum machining L: PC-ABS
Probe : PP: Polypropylene PVDF: polyvinylidene fluoride
Screw size : ECH3XX- M63 x 2
Box Outer Surface : Electrostatic powder paint on alodine coating
Weight : ECH3XXL: 0,75 kg, ECH3XXA: 0,99 kg


Operating Conditions

Ambient Temp.: -20°C +60 °C (Outdoor)
Action Temperature : -20°C +80 °C (Sensor)
Solubility : 1 mm (max.)
Linearity : % 0,2
Max. Measuring : ECH306X - 6 m
ECH308X - 8 m
ECH310X - 10 m
ECH312X - 12 m
ECH315X - 15 m
ECH318X - 18 m
Min. Measuring : ECH306X - 30 cm
ECH308X - 30 cm
ECH310X - 30 cm
ECH312X - 30 cm
ECH315X - 40 cm
ECH318X - 40 cm
Sensor Frequency : ECH3XX- 50 KHz
Beam width : Angle 10° at -3 dB
Compensation : Effect of change of ambient temperature on sound propagation
Vibration : 5-500 Hz 3G RMS random vibration IEC-60068-2-64



A: Sensor surface
B: Probe
C: Screw
D: box
E: cover

Mechanical Mounting




It should be paid attention to make it perpendicular to the surface where measuring to be made in order to provide an accurate measuring

Calculation of minimum distance of the device to the side during its assembly is half of value calculated by multiplying of distance from sensor end to the base with tan12°.

Minimum Distance of the Device to the Side = tan 12 x height / 2

Display and Cable Connections Diagram



General Setup
Press E key until you see TYPE writing on the screen. You can direct it to other menus by using up and down arrow keys. You can exit from the menu by using Back option or Left arrow key.

1. TYPE
To this menu by using arrow keys and press E key. Change measurement shape and unit with the applicable one among LEVEL, VOLUME or DIST ANCE options by using up and down arrow keys. • One of units such as meter, centimeter, inch, feet can be selected for Distance. • One of units such as meter, centimeter, inch, feet can be selected for Level. • It can be selected as cubic meter, liter, US Gallon for Volume.

2. DECIMALS
Go to this menu by using arrow keys and press E key. Enter value of decimal part of the value measured by using up and down arrow keys. This value is a value between 0 and 3; and the part after dot defines decimal part. • DECIMALS value for centimeter and inch can be selected as 1 maximum. • If "VOLUME L" is selected from type menu, DECIMALS can be selected as 1 maximum.

3. ZERO LEVEL (MEASURING DISTANCE)
Go to this menu by using arrow keys and press E key, enter the level which will be measured by using down and up arrow keys. (For example, depth of tank is 800 cm) Zero level is the distance from end of sensor to measuring base. Amount of liquid to be measured is equal to difference of depth (zero level) and the distance from end of sensor towards liquid surface.

Main Level = Zero Level - Distance
Zero Level is a visible menu if LEVEL is selected from Type menu.

4. ZERO OFF (MEASURING OFFSET)
Go to this menu by using arrow keys and press E key, enter the value by using down and up arrow keys. It indicates the offset of the measured distance. The value entered here is subtracted from measured distance and the Main Distance becomes calculated.

Zero OFF is a visible menu if Distance is selected from Type menu.

Main Dis. = Distance- Zero Offset

5. INTERVAL TPS
Go to this menu by using arrow keys and then press E key; enter frequency of signal per second sent for measurement by using arrow keys. This value is between 1 and 8. It is a correct way to enter a value as per measured distance. (For example 1 measurement for 12 m and 4 measurements for 5 m etc.)

6. FILTER (FILTER SETTINGS)
Go to this menu by using arrow keys and press E key; you can change the number of measurements to be added consecutively then divided into measurement number by using down up arrow keys. Maximum 16 measurements can be taken into average. For example, if a system taking one measurement per second is selected as a foursome average, correct measurement score is seen on the screen and in the outputs as one measurement per every 4 seconds.

7. SPAN 4 AND SPAN 20
Go to this menu by using arrow keys and press E key; enter beginning and last measurement value for 4 mA and 20 mA in analog output by using down and up arrow keys. For example, if you do 40 cm as 4 mA and 400 cm as 20 mA for LEVEL CM, your analog output becomes adjusted as 4-20 mA between 40 cm and 400 cm.

8. RELAY 1, 2
Go to this menu by using arrow keys and press E key; you can define operation borders and types of relays by using down up arrow keys. For example: do R1 LOGIC timing type as low for MAIN cm (material height). Do R1 L- 40 cm and R1 L+ 42 cm. Do R1 DELAY (R1 delay) as 2 seconds. In this condition, if measurement value falls below 40 cm, R1 relay pulls after 2 seconds and if the level exceeds 42 cm again, then R1 relay releases it after 2 seconds. It ensures you to adjust L- and L+ hysteresis band. If you try the same process by making R1 LOGIC comparison type as HIGH, R1 relay pulls if the level exceeds 42 cm and releases it if falls below 40 cm.
• If R1 relay is required to be used as fault contact, then "FAULT" should be selected.

R1 DELAY Delay time set
R1 L- Hysteresis band adjustment
R1 L+ Hysteresis band adjustment
R1 LOGIC LOW, HIGH comparison type or FAULT set

9. DELAY
Go to this menu by using arrow keys and press E key; you can define delay time for FAULT contact by using down and up arrow keys. This value is a number between 0 and 15 and fault signal arises at the end of selected time. Fault relay is NC contact, from "R1 LOGIC" section.

10. SHAPE (GEOMETRY SELECTION FOR VOLUME CALCULATION)
Go to this menu by using arrow keys and press E key. Select the relevant one among "RECTANGLE" (RECTANGLE DEPOT), "CYLINDER" (CYLINDRICAL PERPENDICULAR DEPOT), "H-CYLINDER" (CYLINDRICAL HORIZONTAL DEPOT) and "SPHERE" (SPHERICAL DEPOT) which is the tank type to be measured for volume by using up and down arrow keys. Enter DIM_X, DIM_Y, DIM_Z and DIM_D sizes for selected unit.

Shape is a visible menu if VOLUME is selected from Type menu.

11. PARSHAL FLUME
If Flow option is selected, then MainValue value shows speed of parshall flume: m3/S LT/S F3/s and G/L/S. While Main Value appeared, by using up-down keys, it is passed to the indicator where total counter is located. When it is reached to total counter display, TOTAL M3, TOTAL F3 or TOTAL G/L appears as per measuring unit selected and the corresponding value is seen in the line below. The counter value is shown as m3, even if the selected measuring value is Lt/s. While the value shown for m3 is with 1 decimal, it has no decimal for feet3 and gallon. Parshall flume counts the counter up to 99999.9 M3 whatever selected displaying unit it is set (liter, Feet3, Gallon), then turns to zero. In order to reset the counter manually: left arrow key is held pressed for two seconds if any of options of parshall flume is checked as measuring. RESET METERS appears on the screen and it flashes. Counter is reset if E key is pressed while the screen flashes and it is written PARS HALRESET on the screen. Any key other than E key is pressed if it is desired to cancel while the screen flashes or the device restores to normal operation if no key pressed for 4 seconds.

13. COMMUNICATION SETUP
Communication is performed in two parts. For the first part is which is the Modbus (Standard), press E key and then use MODBUS SETUP on the screen. For the second part which is the Hart (optional) it is just after relay setup (see menu diagram)

13.1 MODBUS COMMUNICATION SETUP

13.1.1 Address
Go to this menu by using arrow keys and press E key; you can give a value from 1 to 32 for modbus address by using down up arrow keys.

13.1.2 Format
Go to this menu by using arrow keys and press E key; you can change modbus format as RTU or ASCII by using down and up arrow keys.

13.1.3 BAUD
Go to this menu by using arrow keys and press E key; you can change speed and parity of RS 485 serial communication from 600bps (odd even parity) up to 38400bps by using down and up arrow keys.

13.1.4 Register
Go to this menu by using arrow keys and press E key; you can set the Modbus register type as "MODICON, "32BIT" or "NORMAL" type by using down and up arrow keys.

13.2 HART COMMUNICATION SETTINGS

13.2.1 Hart Address
Come to this menu by using arrow keys and press E key. You can assign a value from 1 to 32 to the device hart address by using up-down arrow keys.

13.2.2 Hart Preambles
Come to this menu by using arrow keys and press E key. You can assign Preamble value greater than 1 to the device by using up-down arrow keys.

13.2.3 Hart Fixed Current
Come to this menu by using arrow keys and press E key. You can fix current output by using up-down arrow keys.

14. ORDERING CODES

ECH306L-24DI ULTRASONIC LEVEL TRANSMITTER & CONTROLLER
Supply Voltage: 24VDC, Signal Out: Analogue 4-20mA & 2 NO Relay Out 250V/1A & Modbus RS485, Accuracy: +/- 2 mm or +/- 0,2 % of set measuring range, Max Measurement Distance: 6M, Sensor Material: PP, Process Connection: MG32X, Process Temperature: -20°C to 80°C, Process pressure: 3bar, Ambient Temperature: -20°C to 80°C, Sensor Protection class: IP68, Transmitter Protection Class: IP67, Transmitter Housing: PC-ABS

ECH308L-24DI ULTRASONIC LEVEL TRANSMITTER & CONTROLLER
Supply Voltage: 24VDC, Signal Out: Analogue 4-20mA & 2 NO Relay Out 250V/1A & Modbus RS485, Accuracy: +/- 2 mm or +/- 0,2 % of set measuring range, Max Measurement Distance: 8M, Sensor Material: PP, Process Connection: MG32X, Process Temperature: -20°C to 80°C, Process pressure: 3bar, Ambient Temperature: -20°C to 80°C, Sensor Protection class: IP68, Transmitter Protection Class: IP67, Transmitter Housing: PC-ABS

ECH310L-24DI ULTRASONIC LEVEL TRANSMITTER & CONTROLLER
Supply Voltage: 24VDC, Signal Out: Analogue 4-20mA & 2 NO Relay Out 250V/1A & Modbus RS485, Accuracy: +/- 2 mm or +/- 0,2 % of set measuring range, Max Measurement Distance: 10M, Sensor Material: PP, Process Connection: MG32X, Process Temperature: -20°C to 80°C, Process pressure: 3bar, Ambient Temperature: -20°C to 80°C, Sensor Protection class: IP68, Transmitter Protection Class: IP67, Transmitter Housing: PC-ABS

ECH312L-24DI ULTRASONIC LEVEL TRANSMITTER & CONTROLLER
Supply Voltage: 24VDC, Signal Out: Analogue 4-20mA & 2 NO Relay Out 250V/1A & Modbus RS485, Accuracy: +/- 2 mm or +/- 0,2 % of set measuring range, Max Measurement Distance: 12M, Sensor Material: PP, Process Connection: MG32X, Process Temperature: -20°C to 80°C, Process pressure: 3bar, Ambient Temperature: -20°C to 80°C, Sensor Protection class: IP68, Transmitter Protection Class: IP67, Transmitter Housing: PC-ABS

ECH315L-24DI ULTRASONIC LEVEL TRANSMITTER & CONTROLLER
Supply Voltage: 24VDC, Signal Out: Analogue 4-20mA & 2 NO Relay Out 250V/1A & Modbus RS485, Accuracy: +/- 2 mm or +/- 0,2 % of set measuring range, Max Measurement Distance: 15M Sensor Material: PP, Process Connection: MG32X, Process Temperature: -20°C to 80°C, Process pressure: 3bar, Ambient Temperature: -20°C to 80°C, Sensor Protection class: IP68, Transmitter Protection Class: IP67, Transmitter Housing: PC-ABS

ECH318L-24DI ULTRASONIC LEVEL TRANSMITTER & CONTROLLER
Supply Voltage: 24VDC, Signal Out: Analogue 4-20mA & 2 NO Relay Out 250V/1A & Modbus RS485, Accuracy: +/- 2 mm or +/- 0,2 % of set measuring range, Max Measurement Distance: 18M, Sensor Material: PP, Process Connection: MG32X, Process Temperature: -20°C to 80°C, Process pressure: 3bar, Ambient Temperature: -20°C to 80°C, Sensor Protection class: IP68, Transmitter Protection Class: IP67, Transmitter Housing: PC-ABS

ECH-FLOW PARSHALL flow measurement software option Add on -F

ECH3XX-X-HART HART Communication option Add on -H

ECH3XX-PVDF PVDF Sensor material option Add on -PVDF Operating Temperature: -40°C to 90°C

ECH3XX-ALUMINIUM ALUMINIUM Housing material option Add on -A Protection Class: IP68

ECH3XX-S-70 Sensor wall mount kit option Add on L=70cm, SS304

ECH3XX-S-150 Sensor wall mount kit option Add on L=150cm, SS304

ECH-XXX-T Transmitter wall mount kit option Add on, SS304 (For Remote Sensor Application)

15. LEGAL COMPLIANCE

CE conformance

EN 61000-6-2:2001 Generic emission standard. Industrial environment.

EN 61000-6-2:2005 Generic immunity standard. Industrial environment.

EN 61010-1:2001 Safety requirements for electrical equipment for measurement, control and laboratory use.

16. WARNINGS AND SAFETY PRECAUTIONS

The level probe should be installed as described in the product manual and the applicable standards IEC 1000-5-1, IEC 1000-5-2, IEC 1131-4. During installation, the source supplying power to the device should be isolated as specified in the EN60204-1 Safety of Machinery standard, should be grounded from only one side and both power inputs should be protected with Type T 1 A fuses and matters such as fitting appropriate voltage protective varistors at the fuse outlets should be considered. It is the sole responsibility of the user to closely adhere to these installation instructions and take all necessary set of measures accordingly. The user shall be liable for any damage and loss that may occur as a result of faulty mounting or installation or use of the device for originally unintended purposes or in consequence of failure on the part of the user to take the necessary set of safety measures. It should not be used alone at a check point where human lives can be endangered. At check points where a high level of safety is required, multiple check points should be provided with mounting of more than one switch at the same measurement level. The manufacturer is not responsible for casualties and damage that may occur as a result of erroneous detections.

17. LIMITED WARRANTY

This product is under our warranty for 2 years, insofar as it is used under such conditions as described in this product manual and provided that it is sent to our service center. This warranty shall not cover any such faults as scratches, crushes, bending or breaks that may occur as a result of mechanical coercions. The user has to make connections with the sleeve using cables with appropriate cross sections, seal the lid in such a manner that tightness is ensured and align the cable direction downwards.

ANNEXES / VOLUME CALCULATIONS

1-Rectangular Prism

Volume= (DIM_X*Distance) x DIM_Y x DIM_Z

DIM_X: Distance of base of depot in rectangular shape to end of level sensor.

DIM_Y: Width of rectangular depot

DIM_Z: Length of rectangular depot

2-Cylinder

Volume= (DIM_X * Distance) x π x $\frac{DIM_D^2}{2}$

DIM_X: Height of cylinder

DIM_D: base diameter of cylinder

3-Horizontal Cylinder

$r = \frac{DIM_D}{2}$, $d = DIM_D$, $Distance = Distance$

11. PARSHAL FLUME

Si l'option Flow est choisie, la valeur Main Value montre la vitesse du courant du parshall flume, passer au compteur Total en employant les touches directionnelles hautes et basses lorsque la valeur Main Value apparaît en m/s/Lt/s/F3/s et GL/s. TOTAL M3, TOTAL F3 ou TOTAL GL apparaît sur l'écran du compteur Total et la valeur sur la ligne inférieure. La valeur du compteur est en m³/s lorsque la valeur de mesure/choix des paramètres est Lt/s. La valeur décimale indiquée pour M3, Fee3 et Galon est sans point. Quoique ce soit l'unité d'indication choisie pour Parshall flume (Litre, Fee3, Galon), le compteur compte jusqu'à 999999.9M et retourne à zéro. Si l'une des options parshall flume est choisie pour la mesure, appuyer deux secondes sur la touche directionnelle gauche pour mettre à zéro manuellement le compteur. Le message RESET METERS apparaît sur l'écran en clignotant. Le compteur est initialisé si on appuie sur la touche E lors du clignotement de l'écran et le message PARS HAL RESET. Appuyer sur une autre touche que la touche E pour renoncer et ne pas appuyer sur aucune touche pendant 4 secondes afin que l'appareil retourne au fonctionnement normal.

13. COMMUNICATION SETUP (PARAMÈTRES DE COMMUNICATION)

Les paramètres de communication sont effectués en deux parties. Pour la première Modbus (Standard), appuyer sur la touche E et les touches directionnelles basse jusqu'à l'apparition du message MODBUS SETUP sur l'écran. La deuxième Hard (Option) est située dans la suite du menu paramètres de Relais (voir diagramme de menu).

13.1 Paramètres De Communication Modbus

Accéder ce menu en employant les touches directionnelles et appuyer sur la touche E, donner une valeur entre 1 et 32 à l'adresse modbus en employant les touches directionnelles hautes et basses.

13.1.2 Format

Accéder ce menu en employant les touches directionnelles et appuyer sur la touche E, modifier le format modbus en RT ou en ASCII en employant les touches directionnelles hautes et basses.

13.1.3 Baud

Accéder ce menu en employant les touches directionnelles et appuyer sur la touche E, modifier la vitesse et la parité (odd – even - no parity) du port de série de communication RS 485 entre 600bps et 38400 bps.

13.1.4 Register

Accéder ce menu en employant les touches directionnelles et appuyer sur la touche E, ainsi on peut modifier le type de registre Modbus en «MODICON 32BIT » ou NORMAL en employant les touches directionnelles hautes et basses.

13.2 Hart Paramètres de communication

Accéder ce menu en employant les touches directionnelles et appuyer sur la touche E, donner une valeur entre 1 et 32 à l'adresse hart de l'appareil en employant les touches directionnelles hautes et basses.

13.2.1 Hart Adress

Accéder ce menu en employant les touches directionnelles et appuyer sur la touche E, donner une valeur entre 1 et 32 à l'adresse hart de l'appareil en employant les touches directionnelles hautes et basses.

13.2.2 Hart Preambles

Accéder ce menu en employant les touches directionnelles et appuyer sur la touche E, donner une valeur Preambles supérieure à 1 à l'appareil en employant les touches directionnelles hautes et basses.

13.2.3 Hart Fixed Current

Accéder ce menu en employant les touches directionnelles et appuyer sur la touche E pour fixer la sortie de courant en employant les touches directionnelles hautes et basses.

14. CODES DE COMMANDE

ECH306L-24DC ULTRASONIC LEVEL TRANSMITTER & CONTROLLER

Supply Voltage: 24VDC, Signal Out: Analogue 4-20mA & 2 NO Relay Out 250V/1A & Modbus RS485, Accuracy: +/- 2 mm or +/- 0,2 % de set measuring range, Max Measurement Distance: 6M, Sensor Material: PP, Process Connection: M63x2, Process Temperature: -20°C to 80°C, Process pressure: 3Bar, Ambient Temperature: -20°C to 80°C, Sensor Protection class: IP68, Transmitter Protection Class: IP67, Transmitter Housing: PC-ABS

ECH308L-24DC ULTRASONIC LEVEL TRANSMITTER & CONTROLLER

Supply Voltage: 24VDC, Signal Out: Analogue 4-20mA & 2 NO Relay Out 250V/1A & Modbus RS485, Accuracy: +/- 2 mm or +/- 0,2 % de set measuring range, Max Measurement Distance: 8M, Sensor Material: PP, Process Connection: M63x2, Process Temperature: -20°C to 80°C, Process pressure: 3Bar, Ambient Temperature: -20°C to 80°C, Sensor Protection class: IP68, Transmitter Protection Class: IP67, Transmitter Housing: PC-ABS

ECH310L-24DC ULTRASONIC LEVEL TRANSMITTER & CONTROLLER

Supply Voltage: 24VDC, Signal Out: Analogue 4-20mA & 2 NO Relay Out 250V/1A & Modbus RS485, Accuracy: +/- 2 mm or +/- 0,2 % de set measuring range, Max Measurement Distance: 10M, Sensor Material: PP, Process Connection: M63x2, Process Temperature: -20°C to 80°C, Process pressure: 3Bar, Ambient Temperature: -20°C to 80°C, Sensor Protection class: IP68, Transmitter Protection Class: IP67, Transmitter Housing: PC-ABS

ECH312L-24DC ULTRASONIC LEVEL TRANSMITTER & CONTROLLER

Supply Voltage: 24VDC, Signal Out: Analogue 4-20mA & 2 NO Relay Out 250V/1A & Modbus RS485, Accuracy: +/- 2 mm or +/- 0,2 % de set measuring range, Max Measurement Distance: 15M, Sensor Material: PP, Process Connection: M63x2, Process Temperature: -20°C to 80°C, Process pressure: 3Bar, Ambient Temperature: -20°C to 80°C, Sensor Protection class: IP68, Transmitter Protection Class: IP67, Transmitter Housing: PC-ABS

ECH315L-24DC ULTRASONIC LEVEL TRANSMITTER & CONTROLLER

Supply Voltage: 24VDC, Signal Out: Analogue 4-20mA & 2 NO Relay Out 250V/1A & Modbus RS485, Accuracy: +/- 2 mm or +/- 0,2 % de set measuring range, Max Measurement Distance: 18M, Sensor Material: PP, Process Connection: M63x2, Process Temperature: -20°C to 80°C, Process pressure: 3Bar, Ambient Temperature: -20°C to 80°C, Sensor Protection class: IP68, Transmitter Protection Class: IP67, Transmitter Housing: PC-ABS

ECH-FLW-PARSHALL flow measurement software option Add on -F

ECH3XX-X-HART HART Communication option Add on -H

ECH3XX-X-PVDF PVDF Sensor material option Add on -PVDF Operating Temperature: -40°C to 90°C

ECH3XX-X-ALUMINUM ALUMINUM Housing material option Add on -A Protection Class: IP68

ECH3XX-S-570 Sensor wall mount kit option Add on L=70cm, SS304

ECH3XX-S-510 Sensor wall mount kit option Add on L=150cm, SS304

ECH-3XX-T Transmitter wall mount kit option Add on, SS304 (For Remote Sensor Application)

15. CONFORMITÉ OFFICIELLE

Conformité CE

EN 61000-6-4: 2001 norme générale d'émission pour l'environnement industriel

EN 61000-6-2: 2005 norme générale d'immunité pour l'environnement industriel

EN61010-1:2001 règles de sécurité pour appareils électriques de mesure, de régulation et de laboratoire

16. AVERTISSEMENTS ET SÉCURITÉ

La sonde de niveau doit être montée conformément aux spécifications de son mode d'emploi et les normes IEC 1000-5-1, IEC 1000-5-2, IEC 1131-4. La source qui alimente l'appareil dans la norme de sécurité de machine EN60204-1 doit être isolée lors du montage, il doit être mis à terre, les deux entrées d'énergie doivent être protégées avec des fusibles 1A type T, faire attention à mettre une varistance au voltage adéquat pour protection contre le voltage excessif à la fiche. L'utilisateur est tenu de se conformer aux règles de montage et prendre les mesures nécessaires. Tous dommages résultant des erreurs de montage, d'utilisation en dehors de sa fonction et de négligence de la sécurité de travail sont sous la responsabilité de l'utilisateur. Ne pas utiliser tout seul dans un point de contrôle susceptible de mettre en danger la vie humaine. Effectuer un contrôle multipoint par plusieurs montages sur le même niveau de mesure dans les points de contrôle nécessitant une sécurité supérieure. Le producteur n'est pas responsable des accidents et dommages survenus des malentendus.

17. ASSURANCE LIMITÉE

Ce produit est sous notre assurance pendant 2 ans, par envoi à notre service sous réserve qu'il soit utilisé dans les conditions spécifiées dans le mode d'emploi. L'assurance ne couvre pas les contraintes mécaniques, les rayures, les flexions, les cassures et les pannes résultant de ces dommages. L'utilisateur doit faire une connexion avec un câble de diamètre convenable et serrer le coupleur d'une façon étanche, fermer le couvercle de l'appareil de sorte d'éviter les fuites, régler le sens de la sortie du câble vers le bas.

ANNEXES / CALCULS DE VOLUME

1-Prisme Rectangulaire

Volume= (DIM_X-Distance) x DIM_Y x DIM_Z

DIM_X: La distance de la base du dépôt rectangulaire au bout du capteur de niveau.

DIM_Y: Largeur du dépôt rectangulaire.

DIM_Z: Longueur du dépôt rectangulaire.

2-Cylindre

Volume= (DIM_X - Distance) x $\pi \frac{(DIM_D)^2}{2}$

DIM_X: Hauteur du cylindre.

DIM_D: Diamètre de la base du cylindre.

3-Cylindre horizontal

$r = \frac{(DIM_D)}{2}$ $d = DIM_D - Distance$

Volume=DIM_L x ($r^2 \times \arccos((r-d)/r)$) - (r-d) x $\sqrt{(2\pi r d) - d^2}$

DIM_X: Distance entre la base du réservoir et le bout du capteur.

DIM_D: Diamètre du cylindre.

DIM_L: Longueur du cylindre horizontal.

4-Sphère

$h = DIM_X - Distance$

Volume= $(\frac{\pi}{3}) \times h^2 \times (1,5 \times (DIM_D-h))$

DIM_X: Distance entre la base du réservoir et le bout du capteur.

DIM_D: Diamètre de la sphère.

5-Parsahl Flume

$h = DIM_X - Distance$

Flow=4 x DIM_D x $h^{(1,522 \times (DIM_D)^{0,5})}$

DIM_D: Largeur du canal.

DIM_X: Distance entre la base du canal et le bout du capteur.


11. PARSHAL FLUME

Si l'option Flow est choisie, la valeur Main Value montre la vitesse du courant du parshall flume, passer au compteur Total en employant les touches directionnelles hautes et basses lorsque la valeur Main Value apparaît en m/s/Lt/s/F3/s et GL/s. TOTAL M3, TOTAL F3 ou TOTAL GL apparaît sur l'écran du compteur Total et la valeur sur la ligne inférieure. La valeur du compteur est en m³/s lorsque la valeur de mesure/choix des paramètres est Lt/s. La valeur décimale indiquée pour M3, Fee3 et Galon est sans point. Quoique ce soit l'unité d'indication choisie pour Parshall flume (Litre, Fee3, Galon), le compteur compte jusqu'à 999999.9M et retourne à zéro. Si l'une des options parshall flume est choisie pour la mesure, appuyer deux secondes sur la touche directionnelle gauche pour mettre à zéro manuellement le compteur. Le message RESET METERS apparaît sur l'écran en clignotant. Le compteur est initialisé si on appuie sur la touche E lors du clignotement de l'écran et le message PARS HAL RESET. Appuyer sur une autre touche que la touche E pour renoncer et ne pas appuyer sur aucune touche pendant 4 secondes afin que l'appareil retourne au fonctionnement normal.

13. COMMUNICATION SETUP (PARAMÈTRES DE COMMUNICATION)

Les paramètres de communication sont effectués en deux parties. Pour la première Modbus (Standard), appuyer sur la touche E et les touches directionnelles basse jusqu'à l'apparition du message MODBUS SETUP sur l'écran. La deuxième Hard (Option) est située dans la suite du menu paramètres de Relais (voir diagramme de menu).

12. DIAGRAMME DU MENU



Campos De Aplicación
La Sonda de Nivel Ultrásónico Orion Echo se usa para las mediciones de volumen y nivel continuo no-contacto de materiales líquidos y sólidos en los tanques abiertos y cerrados. También hay opción de medición de flujo del canal abierto. Hay un juego de teclas impermeable de 4 teclas y el valor medido se muestra en la pantalla.

Selección Para El Campo De Aplicación
El sensor ultrásónico envía pulsaciones cortas del sonido ultrásónico de alta frecuencia (50 KHz) con transductor piezoelectrico. Una parte de la onda del sonido ultrásónico que se refleja impidiendo en la superficie de medida se percibe por el transductor y dependiendo de la velocidad de señal en el aire.

Función
• Tecnología del tratamiento de agua y procesos : Agua, aguas residuales, etc.
• Industria Alimentaria : Bebidas, leche y productos lácteos, etc.
• Industria química y médica : Acidez, bases, pH, cloro, etc. (P/D/F con sensor)
• Control de distancia y movimiento : Trabajo en madera, Ingeniería de Maquinaria

13.1 LAS CONFIGURACIONES DE COMUNICACIÓN DE MODBUS

13.1.1 Hard Address

Venga hasta este menú usando las teclas de flechas y presione la tecla E, usted puede dar un valor entre 1 y 32 a la dirección usando las teclas de flechas Superior - Inferior.

13.1.2 Format

Venga hasta este menú usando las teclas de flechas y presione la tecla E, usted puede cambiar el modbus formato como RT U o ASCII usando las teclas de flechas Superior - Inferior.

13.1.3 Baud

Venga hasta este menú usando las teclas de flechas y presione la tecla E, usted puede cambiar la velocidad del Puerto de comunicación serial RS 485 y su paridad desde 600 bps (par - impar - no paridad) hasta 38400 bps usando las teclas de flechas Superior - Inferior.

13.1.4 Register

Venga hasta este menú usando las teclas de flechas y presione la tecla E, usted puede hacer el tipo de Modbus register como "MODICON", "32BIT" o "NORMAL" usando las teclas de las flechas Superior - Inferior.

13.2 CONFIGURACIONES DE COMUNICACIÓN DE HART

13.2.1 Hart Address

Venga hasta este menú usando las teclas de flechas y presione la tecla E, usted puede dar un valor entre 1 y 32 a la dirección del har del apartado usando las teclas de flechas Superior - Inferior.

13.2.2 Hart Preambles

Venga hasta este menú usando las teclas de flechas y presione la tecla E, usted puede dar un valor entre 1 y 32 a la dirección de har del apartado usando las teclas de flechas Superior - Inferior.

13.2.3 Hart Fixed Current

Venga hasta este menú usando las teclas de flechas y presione la tecla E, usted puede ajustar la salida de corriente usando las teclas de las flechas Superior - Inferior.

14-CÓDIGOS DE PEDIDO

ECH306L-24DC ULTRASONIC LEVEL TRANSMITTER & CONTROLLER

Supply Voltage: 24VDC, Signal Out: Analogue 4-20mA & 2 NO Relay Out 250V/1A & Modbus RS485, Accuracy: +/- 2 mm or +/- 0,2 % de set measuring range, Max Measurement Distance: 6M, Sensor Material: PP, Process Connection: M60X1,5, Process Temperature: -20°C to 80°C, Process pressure: 3Bar, Ambient Temperature: -20°C to 80°C, Sensor Protection class: IP68, Transmitter Protection Class: IP67, Transmitter Housing: PC-ABS

ECH308L-24DC ULTRASONIC LEVEL TRANSMITTER & CONTROLLER

Supply Voltage: 24VDC, Signal Out: Analogue 4-